

FROM (DEPT/ DIVISION): Communications Division 911 Dispatch

PROGRAM: 1509

SUBJECT: Purchase of Batteries for UPS

**Background: Batteries for our Uninterrupted Power Supply are at end of life and need to be replaced. These are a bank of 30 batteries which supply power to 911 equipment when there is a power outage. UPS keeps our equipment running until the Generator comes on for the building. It is a 911 requirement that we have a UPS in place. Oregon Emergency Management will reimburse 30% of cost. Replacement project and cost was anticipated in the 16-17 budget line item 1509-53420**

( ) ACTION REQUESTED: Approval to spend funds in Dispatch Budget.

ATTACHMENTS:

Date: (10-13-2016)

Submitted By: (Kathy Lieuallen)

\*\*\*\*\*For Internal Use Only\*\*\*\*\*

Checkoffs:

- ( ) Exec. Asst.
- ( ) Dept. Head (copy)
- ( ) Human Resources (copy)
- ( ) Budget (copy)
- ( ) Fiscal
- ( ) Legal (copy)
- ( ) (Other - List: )

To be notified of Meeting:  
Kathy Lieuallen  
Robert Pahl

Needed at Meeting:

PLEASE RETURN THIS FORM AND ATTACHMENTS TO Executive Assistant  
\*\*\*\*\*

Scheduled for meeting on: October 19, 2016

Action taken:

\*\*\*\*\*

Follow-up:



Computer Power & Service, Inc.  
 11620 Airport Road, Bldg. C  
 Everett, WA 98204  
 206.782.7090 • cpsiwa.com

**Quote Q7031R1**

<b>TO:</b> Umatilla County 4700 NW Pioneer Place Pendleton, OR 97801	<b>PROJECT:</b> Battery Replacement
<b>Attn:</b> Bret Mueller	<b>LOCATION:</b> Pendleton, OR
<b>e-mail:</b> <a href="mailto:brett.mueller@umrdd.org">brett.mueller@umrdd.org</a>	<b>DATE:</b> 11/09/2015
	<b>Phone:</b> 541-215-2104

Computer Power & Service Inc. is pleased to provide budgetary pricing to replace all batteries associated with Mitsubishi 2033A UPS1 located at the Umatilla County Pendleton office.

Item Description:	Price
<p><b><u>Mitsubishi 2033A 40kVA UPS</u></b></p> <ul style="list-style-type: none"> <li>• Quote includes removal and proper recycling of (30) thirty existing batteries.</li> <li>• Quote includes labor, materials and the installation of (30) new batteries in place of those removed.</li> <li>• All batteries associated with the UPS will be tested for voltage, internal resistance, conductance, and trended over their useful life.</li> <li>• All work to be performed by factory trained &amp; experienced UPS technicians</li> <li>• UPS to be inspected and functional testing performed to insure critical load is protected</li> </ul>	<p><b>\$7,500</b></p>

Notes:

1. Tax is not included
2. Sales are per CPSI Terms and Conditions
3. All work to be performed during normal business hours, M-F 8AM-5PM

Thank you for considering Computer Power & Service, Inc. for this project, and we look forward to your authorization to proceed on the above referenced project. This quote will be subject to review and subsequent revisions after 30 days. If you have any questions, or if we can be of further assistance, please contact me directly at (206) 782-7090.

Regards,

Kendrick Brown  
 Technical Service Manager

1509 - 53420