



Public Swimming Pool Daily Record Sheet

Date: _____ Name of Pool: _____ Owner: _____ Operator: _____

31	30	29	28	27	26	25	24	23	22	21	20	19	18	17	16	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	Day of the Month	Daily Pre-Opening Tests		
																															Main Drain			
																																	Gates and Doors	
																																	Safety Equipment	
																																	Clarity	
																																	pH	
																																Combined Chlorine		
																																Time Checked	Free Chlorine (ppm)	
																																	<ul style="list-style-type: none"> • Outdoor: <ul style="list-style-type: none"> <input type="radio"/> Non-stabilized (hourly) <input type="radio"/> Stabilized (every 4 hours) • Indoor: (every 4 hours) 	
																																	Total Alkalinity (weekly)	
																																	Calcium Hardness (weekly)	
																																	Cyanuric Acid (monthly)	
																																	Flow Rate (GPM)	
																																	Backwashed – Clean Filters	
																																	Soda Ash or Acid Added - specify	
																																	Super-Chlorinated or Oxidized	
																																	Pool Temperature	

Water Quality Parameters – OAR 333-60-200

	<u>MINIMUM</u>	<u>IDEAL</u>	<u>MAXIMUM</u>
Free Chlorine.....	0.8 ppm	1-3.0 ppm	5.0 ppm
Combined Chlorine	0 ppm	0 ppm	0.5 ppm
Bromine	3.0 ppm	3.0-5.0 ppm	8.0 ppm
pH	7.2	7.4-7.6	7.6
Total Alkalinity	80 ppm	100-125 ppm	200 ppm
Cyanuric Acid	0 ppm	30 ppm	150 ppm
Calcium Hardness.....	175 ppm	250 ppm	---

POOL CLOSURE: _____

OTHER INFORMATION: _____

