



1850		1855		1860		1865	
The conductor curve shown is that used for determining tower locations Datum: USC & GS Cond: ACSR DRAKE — M W T 8000 at 1/2" ICE							
UNITED STATES DEPARTMENT OF THE INTERIOR BONNEVILLE POWER ADMINISTRATION PAUL J. RAVER, ADMINISTRATOR							
<b>MCNARY - PENDLETON LINE</b> 230 KV SINGLE CIRCUIT TRANSMISSION LINE MILE 32 FROM McNARY							
PROFILE SERIAL 51132A-D				Approved: <i>Richard F. Higgins</i> Design: F.W.M. Drawn: F.W.M. DATE: 10-8-50 SHEET: 32 OF 40			
I STRUCTURES ADDED		H.A.B. 11-2-50		APPROVED DATE:		FOR CONSTRUCTION E.W.L. P.M. 6/11/51	
NO. REVISION		DATE		APPROVED		Checked: M.S.	
FOR RIGHT-OF-WAY				Ser. 51132 Dwg. 133-01-340-D1			